

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. -05/2024-2025

Dated: 26.03.2025

It is certified that an inspection team headed by **Raghvendra Kumar Mishra, Lab In charge, District Level Water Analysis Laboratory, Deoria** (Name of officers with designation) from **UP Jal Nigam (Rural) Deoria** (Name of Department/office) Inspected the **Seth Anandram Jaipuria School, Kasiya Bypass, Babhani Road, Deoria, Uttar Pradesh 274001** (Name & Address of the school) on **25.03.2025** (Date of inspection) and on the basis of water test report (Attached) Report no: **WTD/020/MAR(24-25)** dated **26.03.2025** of **District Level Water Analysis Laboratory, Deoria** (PHED) lab certified that the **Seth Anandram Jaipuria School, Deoria** (Name of school) has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T.Govt.

This certificate is valid till **01 Year** from date of issue. In case, if there is any change in Drinking Source /gone under maintenance before Expiry of certificate, then this certificate will be no more valid. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory, Deoria.

Signature with Seal.....

Name V. K. VermaDesignation AE

Name & Address of the office/Department

**Uttar Pradesh Jal Nigam Rural, Bhujauli Colony,
Deoria**

Assistant Engineer
Division Office,
UP Jal Nigam (Rural)
Deoria

To

Director,
Seth Anandram Jaipuria School
Beside Gandak Colony, Kasiya Bypass,
Babhani Road, Deoria 274001
(Name & Address of the institution)

NOTE: The certificate is to be issued by authorized officer/PHED Lab/Local bodies.
SETH ANANDRAM JAIPURIA SCHOOL, DEORIA

PRINCIPAL

DIRECTOR



TC-13003

District Level Water Analysis Laboratory

Uttar Pradesh Jal Nigam (Rural), Deoria

Add.- M2, 1st Construction Division, Bhujauli Colony, Deoria 274001**Test Report**

Report No WTD/020/MAR(24-25)

Date 26.03.2025

Page No 01/01

Customer Details

Office Name and Address SETH ANANDRAM JAIPURIA SCHOOL, KASIYA BYPASS, BABHANI ROAD, DEORIA

Ref Letter No & Date --

Basic details of sample

District	DEORIA	Block	DEORIA
Gram Panchayat	DEORIA	Village	DEORIA
Habitation	--	Location	KASIYA BYPASS ROAD, BABHANI ROAD
Water Source	R.O.	WQMIS Id	
Quantity of Sample	1000 ml	Date of S.C.	25.03.2025
Receiving Date	25.03.2025	S. Collector	JAIPURIA SCHOOL DEORIA
Sample Depositor	JAIPURIA SCHOOL DEORIA		
Analysis Start Date	25.03.2025	Analysis Completion Date	26.03.2025

Temperature- 25±3°C

Relative Humidity- 50±15%

Technical Data of Analysis

S. No.	Analysed Parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8) : 2023
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018
3	pH	7.52	6.5	8.5	IS 3025(Part 11): 2022
4	Turbidity (NTU)	0.66	1.0	5.0	IS 3025(Part 10): 2022
5	TDS (mg/l)	78	500	2000	IS 3025(Part 16): 2023
6	Total Alkalinity (mg/l)	60	200	600	IS 3025(Part 23): 2023
7	Total Hardness (mg/l)	48	200	600	IS 3025(Part 21): 2019
8	Calcium (mg/l)	12.80	75	200	IS 3025(Part 40): 2024
9	Magnesium (mg/l)	3.88	30	100	IS 3025(Part 46): 2023
10	Chloride (mg/l)	13.30	250	1000	IS 3025(Part 32): 2019
11	Fluoride (mg/l)	0.18	1.0	1.5	APHA 24 TH Edition 4500-F Method-C (Electrode Method)
12	Nitrate (mg/l)	BDL (0.06<0.1)	45	No relaxation	APHA 24 TH Edition -NO ₃ Method D(UV screening Method)
13	Sulphate (mg/l)	1.47	200	400	APHA 24 TH Edition 4500-SO ₄ Method E(Turbidimetric Method)
14	Iron (mg/l)	BDL (0.01<0.1)	1.0	No relaxation	APHA 24 TH Edition - 3500-Fe Method B(Phenanthroline Method)

#BDL- Below Detection Limit, NA- Not Applicable.

** Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.

Tested By

Email id- labdeoria@gmail.com

RAGHVENDRA K MISHRA (T.M.)

Reviewed By

SONAL MISHRA (QUALITY MANAGER)

Authorized Signatory

Contact No-7905141804

*****End of test report*****

SETH ANANDRAM JAIPURIA
SCHOOL, DEORIA

PRINCIPAL

SETH ANANDRAM JAIPURIA
SCHOOL, DEORIA

DIRECTOR



DISTRICT LEVEL WATER ANALYSIS LABORATORY

UTTAR PRADESH JAL NIGAM(R), BHUJAULI COLONY, DEORIA 274001

BACTERIOLOGICAL SAMPLE TEST REPORT

Rept. No	WTD/020/MAR(24-25)	Date: 26.03.2025	Page No	1/1
Customer Details				
Office Name and Address	SETH ANANDRAM JAIPURIA SCHOOL, KASIYA BYPASS BABHANI ROAD, DEORIA			
Ref Letter No & Date				
Basic details of sample				
District	DEORIA	Block		
Gram Panchayat		Village		
Habitation	BABHANI ROAD, KASIYA BYPASS	Location	BESIDE GANDAK COLONY	
Water Source	R.O.	Sample Code		
Quantity of Sample	500	Date of S.C.	25.03.2025	
Receiving Date	25.03.2025	S. Collector	JAIPURIA SCHOOL	
Sample Depositor	JAIPURIA SCHOOL			
Analysis Start Date	25.03.2025	Analysis Completion Date	26.03.2025	

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH	7.52	-	6.5-8.5	No relaxation	IS 3025 (Part 11):2022
2	Residual Chlorine	NA	mg/L	0.2	1.0	IS 3025 (PART 26) : 2022
3	Total Coli form	Absent	CFU	No relaxation	-	APHA 23 rd Edition :2017
4	E.Coli	Absent	CFU	No relaxation	-	APHA 23 rd Edition :2017

Result : SAFE

Remark: SATISFACTORY

Note 1. This Certificate refers only to the particular sample(s) submitted for testing.

2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless.

SANJEEV KUMAR

Prepared By

Laboratory Contact details: Email-labdeoria@gmail.com



End of the Report

SETH ANANDRAM JAIPURIA
SCHOOL, DEORIA

PRINCIPAL

SETH ANANDRAM JAIPURIA
SCHOOL, DEORIA

DIRECTOR